

Technical Criteria for Non-LID Treatment Facilities

Non-LID Treatment Facilities may be either tree-box-type high-flowrate biofilters or vault-based high-flowrate media filters.

General

- Inflow rate is that generated by a continuous rainfall intensity of 0.2 inches per hour.
- Landscape and non-impervious surfaces should be made self-treating or self-retaining and not drain to treatment facilities, if feasible.
- Use the runoff factors in Table 4-1 (on p. 4-4) of the *Stormwater Technical Guide*.
- The applicant's Stormwater Control Plan (Plan) must include as an attachment a letter from the manufacturer stating the manufacturer has reviewed the Plan, the proposed device meets these technical criteria, and the manufacturer will provide a warranty for two years following activation of the facility.

High-Flowrate Tree-Box-Type Biofilters

- Maximum design surface loading rate of 50 inches per hour.
- Precast concrete construction.
- Inlet design to capture flows at least up to the maximum design surface loading rate and to bypass high flows.
- Minimum media depth of 3.5 feet (may be reduced, but maintaining the same media volume, if required because of inadequate head to discharge point).

Media and facility configuration supports a healthy tree or other vegetation.

Vault-Based High-Flowrate Media Filters

- Replaceable cartridge filters.
- Maximum design filter surface loading rate of 1 gpm/ft²
- Storage volume detains runoff and allows settling of coarse solids prior to filtration.
- Flow through the cartridge filters is controlled by an orifice or other device so that the design surface loading rate is not exceeded.